

To

The Principal

Khalga Collage public
School village Heir
Ajnala Road Distt: Amritsar

No. 473

Dated:- 12/05/2021

Subject:- Building safety certificate for the year 01-04-2021 to 31-03-2022 .

Ref:- Your letter No. 2117 Dated 27-4-2021

The Sub Divisional Engineer, Construction Sub Division, Ajnala vide his letter No 47 Dated 7-5-21 has reported this office that the building of Khalga Collage public school village Heir Ajnala Road in District Amritsar has been visually inspected and found the same provisionally fit for human inhabitation for the year 21-22 i.e. upto 31-03-2022. Your application for safety certificate will only be considered when you will fulfill all the requirement under column 14 of Proforma Part-I.

DA/Proforma I & II


Executive Engineer,
Central Works Divn No. 2,
PWD B&R Br. Amritsar.

Endst.No.

Dated:-

Copy to the Sub Divisional Engineer, Construction Sub Division, Ajnala for information and necessary action w.r.t. his letter No. 47 Dated 7-5-2021

sd/-
Executive Engineer,
Central Works Divn No. 2,
PWD B&R Br. Amritsar.


Principal,
Khalsa College Public School
Heir, Amritsar


Honorary Secretary
Khalsa College
Charitable Society
AMRITSAR

14. Requirement for Fire Protection Arrangements under
NB-Part-IV
(For Building height less than 15 metre)

- | | |
|--|--------|
| a) Whether Hose Real provided | Yes/No |
| b) Whether down comer provided | Yes/No |
| c) Whether Automatic sprinkler provided | Yes/No |
| d) Whether underground static water storage tank of capacity 50000 Ltr.(if converted area exceeds 1500 sqm) | Yes/No |
| e) Whether over head tank of capacity 10000 Ltr.exists (in case of hose real) 20000 Ltr. | Yes/No |
| f) Whether one eclectic and one diesel pump of 3 kg/cum Pressure of capacity 1620 LPM, one electric pump of Capacity 180 LPK exist near underground static tank. | Yes/No |
| g) Whether a pump 3 kg/cum pressure & 450/500 LPM Exist near over head tank. | Yes/No |

Principals
Signature of the Head of School/
Institute **Khalsa College Public School**
Heir, Amritsar

PART-II

(To be filled by the SDE of PWD (B&R) Department)

- a) I have visited the above mentioned school on dated 3/5/2021 and have visually inspected it from all angles of safety and find it fit for normal use as school building.
- b) In case any addition/alteration or expansion and modifications to this buildings is to be carried out, the same be carried out under the supervision of a qualified Engineer and this certificate may be reobtained after the completion from the undersigned.
- c) In case the building is affected by flood, or if there is settlement of walls/ foundations or sagging of roofs etc. immediate inspection of the undersigned be arranged to check the stability and safety of the building.
- d) This building can be safely occupied for normal use upto (indicate upto which it can be used) 31-3-2022

Principals
Principal,
Khalsa College Public School
Heir, Amritsar

RMJCL
Honorary Secretary
Khalsa College
Charitable Society
AMRITSAR

[Signature]
Sub Divisional Engineer
Construction Sub Division
P.W.D. B&R Ajnala

[Signature]